









- I** **RELÈ AD IMPULSI/MONOSTABILE ELETTRONICO, MODULARE**, circuiti indipendenti, fissaggio barra 35 mm (EN 60715).
- GB** **MONOSTABLE STEP OR BISTABLE, ELECTRONIC, MODULAR**, separate and insulated circuits, 35 mm (EN 60715) rail mount.
- F** **RELAIS BI-FONCTION: TELERUPTEUR/RELAIS INSTANTANE, ELECTRONIQUE, MODULAIRE**, circuits indépendants, fixation rail 35 mm (EN 60715).
- D** **ELEKTRONISCHES RELAIS MIT DER WÄHLBAREN FUNKTION BISTABIL ODER MONOSTABIL**, Kontaktkreis durch Basisisolierung zwischen A1-A2, B1-B2-B3 und 11-14 getrennt, für 35 mm - Schiene nach EN 60715.
- NL** **ELEKTRONISCH RELAIS MET INSELBARE FUNCTIE, BISTABIEL OF MONOSTABIEL. MODULAIR**, gescheiden en geïsoleerde circuits, 35 mm railmontage (EN 60715).
- E** **RELÉ ELECTRONICO DE IMPULSOS (BIESTABLE) O MONOESTABLE, MODULAR**, circuitos separados, montaje en guía 35 mm (EN 60715).
- P** **RELÉ DE IMPULSO/MONOESTÁVEL ELETRÔNICO, MODULAR**, circuito independente, montagem em trilho 35 mm (EN 60715).

	13.01.0.012.0000: 12 V AC (50/60Hz)/DC $U_{min} = 9,6 \text{ V AC/DC}$ $U_{max} = 13,2 \text{ V AC/DC}$	13.01.0.024.0000: 24 V AC (50/60Hz)/DC $U_{min} = 19,2 \text{ V AC/DC}$ $U_{max} = 33,6 \text{ V AC/DC}$
	13.01.8.125.0000: (110...125)V AC (50/60)Hz $U_{min} = 88 \text{ V AC}$ $U_{max} = 137 \text{ V AC}$	13.01.8.230.0000: (230...240)V AC (50/60)Hz $U_{min} = 184 \text{ V AC}$ $U_{max} = 264 \text{ V AC}$
	(-10...+60)°C	
	 16 A 250 V ~ μ  2000 W - 230 V AC  750 W - 230 V AC	




- I** **ATTENZIONE:** circuiti separati ed indipendenti: comando a bassa tensione - contatti - rete.
- GB** **ATTENTION:** separate and insulated circuits (control, contacts, power).
- F** **ATTENTION:** circuits séparés et indépendants (commande basse tension, contacts, alimentation).
- D** **HINWEIS:** Basisisolierung zwischen Versorgungsspannung, Ansteuerung und Ausgangskontakt.
- NL** **OPMERKING:** Basisisolatie tussen voeding, aansturing en uitgangskontakt.
- E** **ATENCIÓN:** circuitos de alimentación, mando y contactos del relé, separados e independientes.
- P** **ATENÇÃO:** circuitos separados e independentes (comando de baixa tensão, contatos e alimentação).

- I** Quadro frontale: A = Led relè ON
- GB** Front view: A = Led: relay ON
- F** Tableau frontal: A = Led: relais ON
- D** Vorderansicht: A = LED: Relais in Arbeitsstellung
- NL** Frontaanzicht: A = LED: Relais AAN
- E** Carátula frontal: A = LED: indicación de relé activado
- P** Vista frontal: A = Led: relé com contato fechado



- I** Collegamento relè ad impulsi (BISTABLE)
- GB** Bistable step wiring diagram
- F** Raccordement fonction télerupteur (BISTABLE)
- D** Anschlussbild für Funktion: Bistabil
- NL** Aansluitschema voor functie: BISTABIEL
- E** Conexión como relé de Impulsos (Biestable)
- P** Conexão relé de impulso (BIESTÁVEL)



- I** Collegamento relè monostabile (MONOSTABLE)
- GB** Monostable wiring diagram
- F** Raccordement fonction relais (MONOSTABLE)
- D** Anschlussbild für Funktion: Monostabil
- NL** Aansluitschema voor functie: MONOSTABIEL
- E** Conexión como relé Monoestable
- P** Conexão relé monoestável (MONOESTÁVEL)

